





## EU Type Examination Certificate CML 14ATEX3020X Issue 1

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **LFX/LPX Floodlight Luminaires**
- 3 Manufacturer **Lumenox Limited**
- 4 Address **18-20 The Mansley Centre  
Timothy's Bridge Road  
Stratford Upon Avon  
Warwickshire  
CV37 9NQ, UK**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Certification Management Limited, Unit 1 Newport Business Park, New Port Road, Ellesmere Port CH65 4LZ, UK, Notified Body Number 2503, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:  
EN 60079-0:2012+A11:2013    EN 60079-7:2015    EN 60079-18:2015    EN 60079-31:2014  
EN 60079-28:2015


- 10 The equipment shall be marked with the following:




Ex eb mb op is IIC T6 Gb  
Ex tb op is IIIC T85°C Db  
Ta= -20°C to +40°C




Ex eb mb op is IIC T5 Gb  
Ex tb op is IIIC T100°C Db  
Ta= -20°C to +40°C



Ex eb mb op is IIC T4 Gb  
Ex tb op is IIIC T135°C Db  
Ta= -20°C to +60°C



Ex eb mb op is IIC T4 Gb  
Ex tb op is IIIC T135°C Db  
Ta= -20°C to +65°C



Ex eb mb op is IIC T4 Gb  
Ex tb op is IIIC T135°C Db  
Ta= -20°C to +70°C

Marking is dependent on the model;  
refer to section 11.

*A Snowden*



**CML 14ATEX3020X  
Issue 1**

## **11 Description**

The Lumenox Floodlights are a range of luminaires fitted with LED's and operating at a rated voltage of 110v to 240v. The enclosures are available in 3 sizes (LFX3, LFX6 and LFX12) and two colours (grey or black), all of which have internal and external earth, a number of cable entry points and mounting brackets. The mounting bracket enables the luminaires to be fixed in an orientation pointing down, through 90°, lamp beam horizontal.

The enclosures comprise an aluminium base (housing the LED board, driver board, power supply and connection terminals) and an aluminium lid with toughened glass window and stainless steel or aluminium access panel. The lid and base are fixed together using M6 bolts which pass through the lid and into threaded holes in the base.

The base of the enclosure has a silicone seal permanently fixed into a groove using a silicone adhesive. The top half of the base enclosure houses the LED board/boards and the driver board/boards, which is covered with a black epoxy resin encapsulate. The lower half houses the connection terminals, wiring and the separately potted (black epoxy resin) power supply unit/units. This separately potted PSU may be fitted remotely from the luminaire where appropriate.

The lid has a toughened glass window and stainless steel access panel both secured by screws. Underneath the window and the access panel is a silicone seal permanently fixed into a groove using a silicone adhesive. There are clearance holes to allow fixing to the base and a ridge to allow compression of the seal in the base.

There are 2 size LED boards available 3x3 (9 LEDs) and 4x4 (16 LEDs) each LED is fitted with an individual optic, these optics are available in a range of beam patterns (narrow, medium and wide) to suit the end user application. Each LED inside each optic is separately potted with a transparent silicone encapsulant.

All units available may be supplied with a current of 300mA or 350mA. A complete list of available variants is shown in the table below.



CML 14ATEX3020X  
Issue 1

Model	Type Identifier	Board	Board Qty	Beam Pattern	Current	Ambient (°C)	T Class	T Rating
<b>+40°C Ambient / 300mA</b>								
LFX12	Floodlight	4 x 4	2	Narrow	300mA	-20 to +40	T6	T85 C
LFX12	Floodlight	4 x 4	2	Medium		-20 to +40	T6	T85 C
LFX12	Floodlight	4 x 4	2	Wide		-20 to +40	T6	T85 C
LFX6	Floodlight	4 x 4	1	Narrow		-20 to +40	T5	T100 C
LFX6	Floodlight	4 x 4	1	Medium		-20 to +40	T5	T100 C
LFX6	Floodlight	4 x 4	1	Wide		-20 to +40	T6	T85 C
LFX3	Floodlight	3 x 3	1	Narrow		-20 to +40	T6	T85 C
LFX3	Floodlight	3 x 3	1	Medium		-20 to +40	T6	T85 C
LFX3	Floodlight	3 x 3	1	Wide		-20 to +40	T6	T85 C
<b>+40°C Ambient / 350mA</b>								
LFX12	Floodlight	4 x 4	2	Narrow	350mA	-20 to +40	T5	T100 C
LFX12	Floodlight	4 x 4	2	Medium		-20 to +40	T5	T100 C
LFX12	Floodlight	4 x 4	2	Wide		-20 to +40	T6	T85 C
LFX6	Floodlight	4 x 4	1	Narrow		-20 to +40	T5	T100 C
LFX6	Floodlight	4 x 4	1	Medium		-20 to +40	T5	T100 C
LFX6	Floodlight	4 x 4	1	Wide		-20 to +40	T5	T100 C
LFX3	Floodlight	3 x 3	1	Narrow		-20 to +40	T6	T85 C
LFX3	Floodlight	3 x 3	1	Medium		-20 to +40	T6	T85 C
LFX3	Floodlight	3 x 3	1	Wide		-20 to +40	T6	T85 C
<b>+65°C or +70°C Ambient / 300mA</b>								
LFX12	Floodlight	4 x 4	2	Narrow	300mA	-20 to +70	T4	T135 C
LFX12	Floodlight	4 x 4	2	Medium		-20 to +70	T4	T135 C
LFX12	Floodlight	4 x 4	2	Wide		-20 to +70	T4	T135 C
LFX6	Floodlight	4 x 4	1	Narrow		-20 to +65	T4	T135 C
LFX6	Floodlight	4 x 4	1	Medium		-20 to +65	T4	T135 C
LFX6	Floodlight	4 x 4	1	Wide		-20 to +65	T4	T135 C
LFX3	Floodlight	3 x 3	1	Narrow		-20 to +70	T4	T135 C
LFX3	Floodlight	3 x 3	1	Medium		-20 to +70	T4	T135 C
LFX3	Floodlight	3 x 3	1	Wide		-20 to +70	T4	T135 C
<b>+60°C or +70°C Ambient / 350mA</b>								
LFX12	Floodlight	4 x 4	2	Narrow	350mA	-20 to +60	T4	T135 C
LFX12	Floodlight	4 x 4	2	Medium		-20 to +60	T4	T135 C
LFX12	Floodlight	4 x 4	2	Wide		-20 to +60	T4	T135 C
LFX6	Floodlight	4 x 4	1	Narrow		-20 to +60	T4	T135 C
LFX6	Floodlight	4 x 4	1	Medium		-20 to +60	T4	T135 C
LFX6	Floodlight	4 x 4	1	Wide		-20 to +60	T4	T135 C
LFX3	Floodlight	3 x 3	1	Narrow		-20 to +70	T4	T135 C
LFX3	Floodlight	3 x 3	1	Medium		-20 to +70	T4	T135 C
LFX3	Floodlight	3 x 3	1	Wide		-20 to +70	T4	T135 C



**CML 14ATEX3020X  
Issue 1**

The LPX6 variant, see below options, is identical to the LFX6 variant but is supplied on a mounting frame which allows the unit to be portable. The following models are available:

Model	Type Identifier	Board	Board Qty	Beam Pattern	Current	Ambient (°C)	T Class	T rating
<b>+40°C Ambient / 300mA</b>								
LPX6	Portable	4 x 4	1	Narrow	300mA	-20 to +40	T5	T100°C
LPX6	Portable	4 x 4	1	Medium		-20 to +40	T5	T100°C
LPX6	Portable	4 x 4	1	Wide		-20 to +40	T5	T100°C
<b>+40°C Ambient / 350mA</b>								
LPX6	Portable	4 x 4	1	Narrow	350mA	-20 to +40	T5	T100°C
LPX6	Portable	4 x 4	1	Medium		-20 to +40	T5	T100°C
LPX6	Portable	4 x 4	1	Wide		-20 to +40	T5	T100°C
<b>+65°C Ambient / 300mA</b>								
LPX6	Portable	4 x 4	1	Narrow	300mA	-20 to +65	T4	T135°C
LPX6	Portable	4 x 4	1	Medium		-20 to +65	T4	T135°C
LPX6	Portable	4 x 4	1	Wide		-20 to +65	T4	T135°C
<b>+60°C Ambient / 350mA</b>								
LPX6	Portable	4 x 4	1	Narrow	350mA	-20 to +60	T4	T135°C
LPX6	Portable	4 x 4	1	Medium		-20 to +60	T4	T135°C
LPX6	Portable	4 x 4	1	Wide		-20 to +60	T4	T135°C

#### Variation 1

This variation introduces the following modifications:

- i. To update the certificate reference to the 2014/34/EU Directive.
- ii. To change the name of the manufacturer from Oxalis Ltd. to Lumenox Ltd. The manufacturer address has also changed to that which is shown on this certificate.
- iii. To introduce a new model, LPX6, which is a portable version of the LFX6 model. The Description has been updated to add the new model and its design variants.
- iv. To modify the wording of the Special Condition for Safe Use for clarity.
- v. To update standards to the latest issues/editions
- vi. To add an assessment to EN 60079-28, to specify this standard on the certificate and to include 'op is' in the marking.

#### 12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	31 Oct 2014	R117A/00	Initial issue
1	02 Jan 2017	R1193A/00	Introduction of Variation 1

Note: Drawings that describe the equipment or component are listed in the Annex.



**CML 14ATEX3020X**  
**Issue 1**

### **13 Conditions of manufacture**

The following conditions are required of the manufacturing process for compliance with the certification.

- 13.1 A visual inspection shall be carried out on the encapsulated parts to check for damage, in accordance with EN 60079-18:2009, clause 9.1.

### **14 Special Conditions for Safe Use (Conditions of Certification)**

The following conditions relate to safe installation and/or use of the equipment.

- 14.1 Mounting orientation – Luminaire types LFX3, LFX6 and LFX12 shall only be mounted with the lamp beam facing directly downwards, or rotated up to a maximum of 90° from the downwards position, to the horizontal beam position. It is not permitted that these luminaires are mounted with the beam at an angle above the horizontal position.

## Certificate Annex



**Certificate Number** CML 14ATEX3020X  
**Equipment** LFX/LPX Floodlight Luminaires  
**Manufacturer** Lumenox Ltd.

The following documents describe the equipment or component defined in this certificate:

### Issue 0

Drawing No	Sheets	Rev	Approved Date	Title
LF3 GEN	1	002	31 Oct 2014	LFX3 General Assembly
LFX3LM	1	002	31 Oct 2014	3 series front cover
LFX3BM	1	002	31 Oct 2014	Housing 3 series
LF31-00003	1	001	31 Oct 2014	3 series glass window
LF6 GEN	1	002	31 Oct 2014	LFX6 General Assembly
LFX6LM	1	002	31 Oct 2014	6 series front cover
LFX6BM	1	002	31 Oct 2014	Housing 6 series
LF61-00001	1	001	31 Oct 2014	6 series glass window
LF12 GEN	1	002	31 Oct 2014	LFX12 General Assembly
LFX12LM	1	002	31 Oct 2014	12 series front cover
LFX12BM	1	002	31 Oct 2014	Housing 12 series
LF12-00001	1	001	31 Oct 2014	12 series glass window
LFXG01	1	001	31 Oct 2014	Typical gasketing for LFX Range
LFX-01 CERTLABEL	1	002	31 Oct 2014	LFX Range certification LABEL
LF02-00043	1	002	31 Oct 2014	3, 6 & 12 series terminal cover
3OPTIC	1	002	31 Oct 2014	3 optical assembly
612OPTIC	1	002	31 Oct 2014	6 & 12 optical assembly
LFX3612DLA	1	002	31 Oct 2014	LED board & driver assembly
LF02-00106	1	001	31 Oct 2014	3, 6 & 12 series power supply casting
LFX3612PS	1	002	31 Oct 2014	3, 6 & 12 series power supply
LFX3612EA	1	001	31 Oct 2014	Earth stud
LF3DB	1	002	31 Oct 2014	3 x 3 Driver Board
LF612DB	1	002	31 Oct 2014	4 x 4 Driver Board
ECP150 Critical Components List (2)	7	001	31 Oct 2014	PSU Critical component list
ECP150PS Schematic V1.1	1	001	31 Oct 2014	PSU Schematic
4-Channel LED Driver Schematic (1)	1	005	31 Oct 2014	4 Channel Driver board schematics

## Certificate Annex

**Certificate Number** CML 14ATEX3020X  
**Equipment** LFX/LPX Floodlight Luminaires  
**Manufacturer** Lumenox Ltd.



### Issue 1

Drawing No	Sheets	Rev	Approved date	Title
LPX6FRMA – LPX6 Assembled	1 of 1	0	22 Nov 2016	LPX6 tubular frame and light assembly
LPX6FRM – LPX6 Frame	1 of 1	0	22 Nov 2016	LPX6 tubular frame
LFX02	1 of 1	0	22 Nov 2016	LFX, LPX certification label